



# APPLICATION FOR APPEAL

RECEIVED  
JUN 27 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>July 10, 2012</u>
Time <u>1:30 p.m.</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 1028 E 5th St City: St. Paul State: MN Zip: \_\_\_\_\_

Appellant/Applicant: Mary Jo Connelly (owner) Email \_\_\_\_\_

Phone Numbers: Business 651-222-8701 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: Brian Niles Brian Niles, contractor 651-335-9445 Date: 6/9/2012

Name of Owner (if other than Appellant): Mary Jo Connelly

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O \_\_\_\_\_
- Summary/Vehicle Abatement \_\_\_\_\_
- Fire C of O Deficiency List \_\_\_\_\_
- Fire C of O: Only Egress Windows \_\_\_\_\_
- Code Enforcement Correction Notice \_\_\_\_\_
- Vacant Building Registration \_\_\_\_\_
- Other Windows - Egress window Non Compl. Determin.
- Other \_\_\_\_\_
- Other \_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 27, 2012

APPEAL PROPERTY ADDRESS: 1028 5TH ST E  
APPLICANT NAME: NILLES BUILDERS INC  
PHONE NUMBER: 651-222-8701  
PERMIT NUMBER: 12 047016  
TYPE OF WINDOW Double Hung  
NUMBER OF WINDOWS 2

<b>Total Glazed Area</b> Minimum 5 Square Feet	8.3sf	<b>Difference from Required Area</b>	+3.3
<b>Width of Opening</b> Minimum 20 Inches	23 ½	<b>Difference from Required Opening</b>	+3 ½
<b>Height of Opening</b> Minimum 24 Inches	21	<b>Difference from Required Opening</b>	-3
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 6-27-12