

✓ Scanned



APPLICATION FOR APPEAL

RECEIVED

JUN 27 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-12-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

re mailed

Address Being Appealed:

Number & Street: 2163 Falcon Ave City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Sharon Lemay

Address (if not Appellant's): 2163 Falcon Ave

Phone Numbers: Business _____ Residence 651-414-9741 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows that will not comply w/ Egress Policy. Operable height will be short by 6". Operable width & overall glazed area will be exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 24, 2011

APPEAL PROPERTY ADDRESS: 2163 FALCON AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 243511

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	12.4 sq. ft.	Difference from Required Area	+7.4 sq. ft.
Width of Opening Minimum 20 Inches	36"	Difference from Required Opening	+16"
Height of Opening Minimum 24 Inches	18"	Difference from Required Opening	-6"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on the information provided above determination to be made by legislative hearing officer.

Reviewed by: dd