



# APPLICATION FOR APPEAL

RECEIVED  
DEC 15 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, JANUARY 3, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

walk-in

## Address Being Appealed:

Number & Street: 894 Armstrong City: St Paul State: MN Zip: 55102

Appellant/Applicant: The Window Store HI Email Michelle@homesureinc.com

Phone Numbers: Business 612 353-5780 Residence \_\_\_\_\_ Cell 763-477-1820

Signature: Derek Janberg Date: 12-15-11

Name of Owner (if other than Appellant): Rosemarie Cook

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence 651 225-9709 Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Rosemarie does not want to switch to a casement window style because it will not go with the style of her older home. The PH window we want to install complies with code on Height + width. It just misses on total egress opening area. it is 4.5570, so it is very close to compliance

Book 1

Select a Model

<b>(Model 0201)</b>		0201
<b>Excalibur Double Hung</b>		
Top Sash Width	28.5000	
Top Sash Height	29.1875	
Bottom Sash Width	29.5000	
Bottom Sash Height	30.1875	
Top Glass Width	26.8125	
Top Glass Height	27.5000	
Bottom Glass Width	27.8125	
Bottom Glass Height	28.5000	
Screen Width	28.0625	
Screen Height	30.4375	
Top Sash Weight (Plus 5 lb)	26 lb	
Top Balance Size (C.F)	67GN	
Top Balance Size (Spiral)	25-11R	
Bottom Sash Weight	23 lb	
Bottom Balance Size (C.F)	66YW	
Bottom Balance Size (Spiral)	29-10R	
Egress Opening Width	27.3440	
Egress Opening Height	24.0000	
Egress Opening Area (sq.ft.)	4.5570	

Min. W: 11	Max W: 52	
Min. H: 20	Max H: 84	Max UI: 132
Exact Size		
Width:	31.75	31.75
Height:	61.5	61.5
Extrusion:	Select Extrusion	<< For Arch-Top Models Only
Opening:	Exact Size	
Type:	Standard	
Screen:	Half	
Glass:	Double Strength (3 mm)	

AC Sash Calculator

*[Handwritten scribbles]*

*[Handwritten scribbles]*



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 12-15-11

APPEAL PROPERTY ADDRESS: 849 Armstrong AVE St Paul 55102

APPLICANT NAME: The Window Store Home Inc. PHONE NUMBER: 763 477-1820

PERMIT NUMBER: 2011306363

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: ~~1219~~ 1465.11

DIFFERENCE FROM REQUIRED AREA: \_\_\_\_\_

WIDTH OF OPENING: 27.344"

DIFFERENCE FROM REQUIRED OPENING: + 7.344

HEIGHT OF OPENING: 24.000"

DIFFERENCE FROM REQUIRED OPENING: Same as required

HEIGHT OF OPENING TO FINISHED FLOOR: 20"

DIFFERENCE FROM MAXIMUM HEIGHT: \_\_\_\_\_

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

FROM: \_\_\_\_\_