



# APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

NOV 05 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11/16/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1931 Fourth Street East City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Jeremy Thompson Email jeremy.jdt@gmail.com

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 952-215-2763

Signature: [Signature] Date: Nov 8, 2010

Name of Owner (if other than Appellant): [Redacted]

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL

INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 29, 2010

APPEAL PROPERTY ADDRESS: 1931 4TH ST E

APPLICANT NAME: THOMPSON REMODELING LLC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 896062

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Two

Total Glazed Area	1@11.7 sq. ft	Difference from Required Area	+6 sq. ft
	1@ 8.5 sq. ft		+2.8 sq. ft
Width of Opening	33" & 24"	Difference from Required Opening	+13" & 4"

Height of Opening	Both 22.5"	Difference from Required Opening	-1.5"
Height of Opening to Finished Floor	Both OK	Difference from Maximum Height	

COMMENTS:

Reviewed by: David Nelson