



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 7, 2016

BRUCE BENNETT
1290 FORD PKWY
ST PAUL MN 55116-2208

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1672 THOMAS AVE
Ref. # 121260

Dear Property Representative:

Your building was determined to be a registered vacant building on July 7, 2016. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. Interior - Throughout - SPLC 34.14 (2), 34.34 (5) - Provide an approved electrical service adequate to meet the buildings needs. This work requires a permit(s), call DSI at (651) 266-9090.-
2. Interior - Throughout - SPLC 33.05 - Uncertified portions of the building must not be occupied until inspected and approved by this office.-
All permits must be inspected and approved for electrical, plumbing, mechanical, and building. This home will be a complete remodel. Home has been vacant for more than one year.
3. Interior - Throughout - MFGC 503 - Provide, repair or replace the fuel equipment vent or vent liner to develop a positive flow adequate to convey all products of combustion to the outside. This work requires a permit(s). Call DSI at (651) 266-8989.-
All mechanical/venting work requires a permit.
4. Interior - Throughout - SPLC 34.11(4), 34.34(1) SPC 4715.0200A - Provide an adequate water supply to all water closets, sinks, showers and tubs. All plumbing work requires a permit.

5. Interior - Throughout - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the walls in an approved manner. -All walls, flooring, ceilings, framing, sheetrock must be inspected under permit.

6. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

A.J. Neis
Fire Inspector

Ref. # 121260