



APPLICATION FOR APPEAL

RECEIVED

JAN 06 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Jan. 17, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

walk in

Address Being Appealed:

Number & Street: 1568 CHAMBERST City: ST PAUL State: MN Zip: 55106

Appellant/Applicant: Mike Lacroix and Rick Nyquist Email: TWINCITYWINDOW@HOTMAIL.COM

Phone Numbers: Business 612-251-6829 Residence _____ Cell 612-940-1613 (Mike)

Signature: [Signature] Date: 1-6-2012

Name of Owner (if other than Appellant): NICOLE G. KAPLAN

Address (if not Appellant's): 21901 HOMESTEAD TR. CORCORAN MN 55340 ^{← TWINCITY WINDOW}

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration

☒ Other

☐ Other

☐ Other

EGRESS WINDOW NON-COMPLIANCE - WINDOWS
ARE LARGEST SIZE OF MANUFACTURED, IN EXISTING
OPENINGS. MEETS STATE BUILDING CODES
EASIER TO OPEN ANY USE THAN PREVIOUS
WINDOWS.

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 3, 2012

APPEAL PROPERTY ADDRESS: 1568 CHAMBER ST

APPLICANT NAME: TWIN CITY WINDOW REPLACEMENT CO

PHONE NUMBER: 612-251-6829

PERMIT NUMBER: 10 939894

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Two

Total Glazed Area Minimum 5 Square Feet	7.2 sq. ft.	Difference from Required Area	+2.0 sq. ft.
Width of Opening Minimum 20 Inches	37"	Difference from Required Opening	+17"
Height of Opening Minimum 24 Inches	14"	Difference from Required Opening	-10"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	

COMMENTS: Please submit this with 25\$ check to office listed above for review.

Reviewed by: David Nelson 266-9027