



APPLICATION FOR APPEAL

RECEIVED

SEP 15 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>9-20-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1217 Woodbridge City: St Paul State: MN Zip: 55117

Appellant/Applicant: TRANG VO Email: Vincentation@gmail.com

Phone Numbers: Business (651) 379 5003 Residence (651) 270 7332 Cell (651) 270 7332

Signature: TRANG VO Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

① Egress window (please see attached)

② 2 bedrooms at 2nd floor
please see pictures and drawing.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE:

APPEAL PROPERTY ADDRESS: 1217 Woodbridge St

APPLICANT NAME: TRANG VO

PHONE NUMBER: (651) 270-7332

PERMIT NUMBER: 20-11 244326

TYPE OF WINDOW DH

NUMBER OF WINDOWS 1

Total Glazed Area	8	Difference from Required Area	+3
Width of Opening	17.5"	Difference from Required Opening	-2.5"
Height of Opening	26"	Difference from Required Opening	+4"
Height of Opening to Finished Floor	_____	Difference from Maximum Height	_____

COMMENTS:

Reviewed by: