



APPLICATION FOR APPEAL

RECEIVED
FEB 09 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>2-22-11</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

mailed 2-9-11

Address Being Appealed:

Number & Street: 1169 Rose City: St Paul State: 55106 Zip: MN

Appellant/Applicant: DAVE ENGSTROM Email _____

Phone Numbers: Business 651-214-5263 Residence 14805 475th St S AF Town MN Cell Same

Signature: *[Signature]* Date: 2-4-11

Name of Owner (if other than Appellant): AFFORDABLE Properties LLC

Address (if not Appellant's): Same

Phone Numbers: Business Same Residence Same Cell Same

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice 2nd Floor Windows - size is off by 2" - See Attach
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

January 24, 2011

DAVE ENGSTROM
PROPERTY MGR
14805 -- 45TH ST S
AFTON MN 55001-9689

FIRE INSPECTION CORRECTION NOTICE

RE: 1169 ROSE AVE E
Ref. #116190
Residential Class: A

Dear Property Representative:

Your building was inspected on January 21, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on February 14, 2011 at 1:30 pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 2ND FLOOR - BEDROOM - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Bedroom window on 2nd floor measured at 19 inches openable height by 32 inches openable width

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: jacqueline.girling@ci.stpaul.mn.us or call me at 651-266-8981 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Jackie Girling
Fire Inspector

Reference Number 116190