



APPLICATION FOR APPEAL

RECEIVED
JAN 27 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday, <u>2-14-12</u>	
Time <u>1:30</u>	
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

Address Being Appealed:

Number & Street: 1526 Albert St N City: S Paul State: MN Zip: 55108

Appellant/Applicant: Pella, Meghan Booker Email: bookerme@pella.com

Phone Numbers: Business 612-741-9218 Residence _____ Cell _____

Signature: [Signature] Date: 1/25/12

Name of Owner (if other than Appellant): Janna & Marcus Schneider

Address (if not Appellant's): 1526 Albert St N

Phone Numbers: Business _____ Residence _____ Cell 651-338-9382

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List
 - Fire C of O: Only Egress Windows
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other
 - Other
 - Other
- Egress non-compliance appeal in residential replacement



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 1/25/12

APPEAL PROPERTY ADDRESS: 1526 Albert St N.

APPLICANT NAME: Janna & Marcus Schneider PHONE NUMBER: 651-338-9382

PERMIT NUMBER: n/a

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 4

TOTAL GLAZED AREA: 4.19ft² DIFFERENCE FROM REQUIRED AREA: .8'

WIDTH OF OPENING: 26 DIFFERENCE FROM REQUIRED OPENING: n/a

HEIGHT OF OPENING: 23 1/4 DIFFERENCE FROM REQUIRED OPENING: n/a

HEIGHT OF OPENING TO FINISHED FLOOR: 36" DIFFERENCE FROM MAXIMUM HEIGHT: n/a

RECOMMENDATION (IF APPLICABLE): Pella is requesting appeal on 2 bedroom wdws that meet minimums on height & width of clear opening but are coming short on the total square footage of the opening. (Total Glazed area fully meets the 5.1²ft requirement).

FROM: _____