

## CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615

EMAIL: <a href="mailto:legislativehearings@ci.stpaul.mn.us">legislativehearings@ci.stpaul.mn.us</a>
PHONE: (651) 266-8560 FAX: (651) 266-8574

October 29, 2010

Jim & Lisa Campbell 2024 Oakridge Street St. Paul, MN 55119

Re: Appeal for property at <u>1596 McLean Avenue</u>.

File ID: ALH 10-246

Dear Mr. & Mrs. Champbell:

This is to confirm that on October 26, 2010 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended denying the appeal on the 36 inches clearance in front of all electrical panel (Item 8). You may provide a floor plan by November 2, 2010 for her review if you wish to do so. Also, if you wish to bring this issue to the City Council, please let me know and a hearing can be scheduled.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang

cc: Fire Supervisors (email)

Pat Fish (email)