



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8585

RECEIVED

DEC 05 2014

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number 794120)
- Copy of the City-issued orders/letter being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In
for abatement orders only: Email OR Fax

HEARING DATE & TIME
(provided by Legislative Hearing Office)

Tuesday, 12-16-14

Time 11:30 AM

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2049 4th St E. City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Lao Toua Moua Email: ltmoua28@hotmail.com

Phone Numbers: Business _____ Residence _____ Cell 651-226-5896

Signature: Lao Toua Moua Date: 12-04-14

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

Order of Vacate. I bought the house about 3 years now. The house was approved by the City ready to move in for the buyer.

I work for a Company Call CPI,
we make gift cards, with the
Holiday we been so busy, working
12 hrs and weekend I haven't
had Time to fixed the house.

Starting 12-23-14 to 1-05-~~2015~~
I will take off work to
work on the house to meet
City's standard. I ask for
more Time til then.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

December 3, 2014

LAO TOUA MOUA
1539 SHERWOOD AVE
ST PAUL MN 55106-2213

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 2049 4TH ST E
Ref. # 121908

Dear Property Representative:

Your building was inspected on December 2, 2014, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

A reinspection will be made on December 31, 2014 at 2:30pm or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Basement - Laundry room - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was an empty smoke detector bracket in the laundry room.
2. Basement - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.-
3. Basement - MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.-

4. First floor - Bathroom - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the walls in an approved manner. -Paint the wall and ceiling in the bathroom.
5. First floor - North East bedroom - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was a smoke detector inside of the bedroom that would not sound.
6. First floor - South East bedroom - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was a smoke detector inside of the bedroom that would not sound.
7. First floor - South entry - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.-
8. First floor - Hallway - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was a non working smoke detector next to the functioning one.
9. Garage - South side - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.-The window frame is rotting out.
10. Garage - South side under window - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.-
11. Garage - South side under window - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-
12. Garage - SPLC 71.01 - Provide address numbers on building.-
13. Second floor - East bedroom - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was a smoke detector inside of the room that was not sounding.
14. Second floor - East bedroom - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.-
15. Second floor - Hallway - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.-

16. Second floor - West bedroom - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was an empty smoke detector inside of the room.
17. Second floor - West bedroom - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the ceiling in an approved manner.-
18. Second floor - Hallway - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-There was an empty smoke detector bracket in the second floor hallway.
19. South side - Stairs - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-The stairs have separated from the house and there is exposed wood behind the stairs.
20. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
21. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: george.niemeyer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 – 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

George Niemeyer
Fire Inspector

Ref. # 121908