



# APPLICATION FOR APPEAL

RECEIVED  
JUN 25 2012  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

**YOUR HEARING Date and Time:**

Tuesday, July 10, 2012

Time 1:30 p.m.

**Location of Hearing:**  
Room 330 City Hall/Courthouse

called + spoke to owner 6-25-12 - rfn  
mailed 6-25-12 - rfn

## Address Being Appealed:

Number & Street: 880 3rd St. E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Kao Yang Email \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651-434-2988

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Name of Owner (if other than Appellant): \_\_\_\_\_

<sup>mailing</sup>  
Address (if not Appellant's): 1050 Cottonwood Road, Hudson, WI 54016

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

we bought the house as is and was  
pass when they came and inspect  
the window.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

June 6, 2012

KAO YANG  
1050 COTTONWOOD RD  
HUDSON WI 54016-7117

### FIRE INSPECTION CORRECTION NOTICE

RE: 880 3RD ST E  
Ref. #116295  
Residential Class: C

Dear Property Representative:

Your building was inspected on June 5, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

**A re-inspection will be made on July 3, 2012 at 2:00 pm.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

1. 1st Floor - NE Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung window opening.  
H 21 in. - W 34 in.  
Glazed area.  
H47 in. - W 34 in.

An Equal Opportunity Employer

2. 1st Floor - SE and SW bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-2 Double hung window openings.

H 17.5 in. - W 30 in.

Glazed area.

H40 in. - W 30 in.

3. 1st Floor - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

4. Basement - NEC 440.13 - For cord-connected equipment such as room air conditioners, household refrigerators and freezers, drinking water coolers, and beverage dispensers, a separable connector or an attachment plug and receptacle shall be permitted to serve as the disconnecting means. The appliance must plug directly into a permanent outlet.-2 Freezers on power strip. Must be plugged directly into wall outlet.

5. Front door - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.

6. Hallway and SE bedroom - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.

7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

8. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [mike.cassidy@ci.stpaul.mn.us](mailto:mike.cassidy@ci.stpaul.mn.us) or call me at 651-266-8984 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy