



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

May 8, 2012

Daniel Schmidt
Public Health
2785 White Bear Ave N, Ste. 350
Maplewood MN 55109

VIA EMAIL: daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 1081 Stinson

Dear Mr. Schmidt:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, has reviewed the above-referenced matter and recommended that the City Council grant a 3-inch variance on the openable height of two double hung egress bedroom window measuring 21.9 inches high by 23.1 inches wide.

This matter will be on the City Council Public Hearing on Wednesday, June 6, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, since the appeal has been granted you don't need to appear.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)