

\$25.00



APPLICATION FOR APPEAL

RECEIVED
MAR 23 2011
Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
CITY CLERK Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>4-12-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1214 James Ave City: St Paul State: MN Zip: 55105

Appellant/Applicant: Window Concepts of MN Email _____

Phone Numbers: Business _____ Residence _____ Cell _____

Signature: Jeanne Burr Date: 3/11/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows State building code states that window same style & size meets code
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: March 1, 2011

Amy Brisben

APPEAL PROPERTY ADDRESS: 1214 JAMES AVE

APPLICANT NAME: WINDOW CONCEPTS OF MINNESOTA INC

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 794034

TYPE OF WINDOW Double hung

NUMBER OF WINDOWS 2 Bedrooms

Total Glazed Area Minimum 5 Square Feet	1. 8.5 sq. ft. 2. 4 sq. ft.	Difference from Required Area	1. +3.5 sq. ft. 2. -1 sq. ft.
Width of Opening Minimum 20 Inches	1. 32" 2. 25.5"	Difference from Required Opening	1. +8" 2. +1.5"
Height of Opening Minimum 24 Inches	1. 19.5" 2. 11.5"	Difference from Required Opening	1. -4.5" 2. -12.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	28" 44"	Difference from Maximum Height	+20"ok +4"ok

COMMENTS:

Reviewed by: David Tank