



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/19/10

APPEAL PROPERTY ADDRESS: 1166 Juliet

APPLICANT NAME: _____ PHONE NUMBER: _____

PERMIT NUMBER: _____

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2 separate bed room windows

TOTAL GLAZED AREA: _____

DIFFERENCE FROM REQUIRED AREA: _____

WIDTH OF OPENING: 24 1/2"

DIFFERENCE FROM REQUIRED OPENING: + 2 1/2

HEIGHT OF OPENING: 22"

DIFFERENCE FROM REQUIRED OPENING: -2

HEIGHT OF OPENING TO FINISHED FLOOR: 28"

DIFFERENCE FROM MAXIMUM HEIGHT: NA

RECOMMENDATION (IF APPLICABLE): 1st Floor Bedroom windows.

Recommended approval

David Kenyon

FROM: [Signature]