



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 12, 2010

Jim and Lisa Campbell  
2024 Oakridge Street  
St. Paul, MN 55119

VIA EMAIL: [lcampbell02@sjm.com](mailto:lcampbell02@sjm.com)

Re: Appeal for property at 1596 McLean Avenue  
ALH 10-246

Dear Mr. & Mrs. Campbell:

This is to confirm that on November 10, 2010, Marcia Moermond, Legislative Hearing Officer reviewed the proposed floor plan alteration for the laundry room submitted by you and based on the documentation, she recommended granting a 12-inch clearance in front of the electrical panel.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Hearing Coordinator

cc: Fire Supervisors  
File

