



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

361

October 16, 2012

10-309864

Home Solutions Partners IV Reo LLC
8117 Preston Rd Ste 160
Dallas TX 75225-6399

Fannie Mae
14221 Dallas Pkwy #1000
Dallas TX 75254

Peterson, Fram & Bergman
55 E 5th Street E #800
St Paul MN 55101

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

533 BURGESS ST

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Denslows Addition To Thecity Ex Part W Of A L Run At Ra From A Pt On S L Of And 37 68/100 Ft From Sw Cor Lot 18 And Beg At Ne Cor Of Lot 17 Th W 6 88/100 Ft Th Swly 54 83/100 Ft Par With Sely L Of Sd Lot 17 Th S Par With E L Of Sd Lot 18 To Sely L Of Sd Lot 17 Th Nely On Sd Sely L To

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On October 10, 2012 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

Description of Building: one-story wood frame duplex.

The following Deficiency List is excerpted from the May 18, 2010, Code Compliance Report.

BUILDING

- Insure basement cellar floor is even, cleanable and all holes are filled
- Tuck Point interior/exterior of foundation as necessary
- Dry out basement and eliminate source of moisture
- Remove mold, mildew and moldy or water damaged materials
- Install 20 minute fire rated doors, with self closing device, between common areas and individual units.
- Maintain one hour fire separation between dwelling units and between units and common areas
- Install handrails and guardrails at all stairways, including basement stairways, and return handrail ends to the wall or newel post per attachment.
- Install tempered or safety glass in window over stair landing to code
- Install tempered or safety glass in window over stairway to code
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary
- Provide complete storms and screens, in good repair for all door and window openings
- Provide and operable latching device for all windows
- Provide operable hardware at all doors and windows
- Provide thumb type deadbolts for all entry doors. Remove any surface bolts
- Repair or replace damaged doors and frames as necessary, including storm doors
- Weather seal exterior doors
- Install floor covering in bathroom and kitchen that is impervious to water
- Repair walls, ceiling and floors throughout, as necessary
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedure if lead base paint is present (See St Paul Legislative Code, Chap. 34 for additional information).
- Install attic insulation according to applicable code
- Air-seal and insulate attic access door in an approved manner
- Provide smoke detectors per the MN Building Code and carbon monoxide detectors per State Law.
- Habitable rooms with new usage and replaced windows shall have glass area equal to 8% of floor area, or a minimum of 8 sq. ft, one-half of which shall operate; and all bedroom windows shall meet emergency escape requirements (20 inch minimum opening width, 24 inch minimum opening height, and minimum net glazed area of 5.7 sq. ft.)
- Provide general clean-up of premises
- Repair siding, soffit, fascia, trim, etc. as necessary
- Maintain 6 inches minimum clearance between wood and soil, sloped to drain away from foundation of dwelling.
- Provide proper drainage around house to direct water away from foundation of house.
- Install downspouts and a complete gutter system.
- Install rain leaders to direct drainage away from foundation.

- Provide durable, dustless parking surface as specified in the zoning code.
- Close in open stair risers to maintain an opening no greater than 4 inches
- Replace rotted wall on east side of front entry under front deck.
- Install floor in kitchen sink cabinet.
- Remove floor covering from lower unit and have re-inspected for rot and mold damaged.
- Remove carpet from basement and lower unit.
- Provide 1 hour fire rated separation between unit floor and ceilings and remove suspended ceiling from lower unit.
- Front main level bedroom in upper unit install egress compliance window.
- Have water damaged materials removed and drainage and water infiltration issues repaired and have testing company check air quality for safety.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Verify that circuit breaker amperage matches wire size
- Properly strap cables and conduits in basement
- Install globe-type enclosed light fixture on all closet lights
- Remove all cord wiring
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Remove any 3-wire ungrounded outlets and replace with 2-wire or ground 3-wire to code
- Install hard-wired, battery backup smoke detector per bulletin 80-1 and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Check building write-up for fire resistance requirements if both panels are in the common area in a basement or move 2nd unit electrical panel board to the second unit
- Throughout building, install outlets and light fixtures as specified in Bulletin 80-1.
- Rewire hot water heater and condensate pump circuits to code.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the 2008 NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - not fired or in service also the power vent venting is incorrect
- Basement - Water Meter - support meter properly
- Basement - Water Piping - boiler fill water line requires backflow assembly or device
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping
- Basement - Gas Piping - add appropriate hangers
- Basement - Soil and Waste Piping - add appropriate hangers
- First Floor - Tub and Shower - faucet is missing, broken or parts missing
- First Floor - Tub and Shower - provide stopper
- Second Floor - Tub and Shower - Provide access
- Second Floor - Tub and Shower - provide stopper
- Exterior - Lawn Hydrants - Requires backflow assembly or device
- Obtain plumbing permits prior to commencement of work.
- Clean and Orsat test furnace and boiler burners. Check all controls for proper operation. Check furnace heat exchanger for leaks; provide documentation from a licensed contractor that the heating units are safe.
- Provide adequate combustion air and support duct to code.
- Provide appropriate size operable window in bathrooms or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- All supply and return ducts for warm air heating system must be clean before final approval for occupancy. Provide access for inspection of inside of ducts or provide documentation from a licensed duct-cleaning contractor that the duct system has been cleaned.
- Repair and/or replace heating registers as necessary.
- Repair or replace fin tube radiation and covers as needed.
- Install stop valve on each side of the back flow preventer.
- A hydronic mechanical permit is required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **November 15, 2012** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Matt Dornfeld** between the hours of 8:00 and 9:30 a.m. at **651-266-1902**, or you may leave a voice mail message.

Sincerely,

Matt Dornfeld
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council