



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

May 5, 2011

Robert Bray
8101 – 113th St Ct S
Cottage Grove MN 55016

VIA EMAIL: robertebray@comcast.net

Re: Appeal for property at 2068 Suburban Avenue
File ID #: ALH 11-410

Dear Mr. Bray:

This is to confirm that on May 3, 2011, Marcia Moermond, Legislative Hearing Officer, reviewed the photograph of the egress window provided by you and based on the documentation, Ms. Moermond recommended granting an 8-inch variance on the openable height of the egress windows in the main floor northeast, southeast, and southwest bedrooms.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
File