



# APPLICATION FOR APPEAL

RECEIVED

MAY 14 2012

CITY CLERK

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- ☐ \$25 filing fee payable to the City of Saint Paul  
(if cash: receipt number \_\_\_\_\_)
- ☐ Copy of the City-issued orders or letter which  
are being appealed
- ☐ Attachments you may wish to include
- ☐ This appeal form completed
- ☐ Walk-In OR ☐ Mail-In

**YOUR HEARING Date and Time:**

Tuesday, 5-22-12

Time 1:30 P.M.

**Location of Hearing:**

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1922 Clear Ave City: St. Paul State: MN Zip: 55119

Appellant/Applicant: John Rosener Email: john.Rosener@thelathomeservices.com

Phone Numbers: Business 612-802-9176 Residence — Cell —

Signature: [Signature] Date: 4/27/12

Name of Owner (if other than Appellant): Famata King

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence 651-246-6764 Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/  
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

We replaced 1 Double Hung window  
(Like for Like) in a twin D/H configuration.  
Home owner wanted new window to match.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

# 5968240

DATE: April 19, 2012

APPEAL PROPERTY ADDRESS: 1922 CLEAR AVE

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 770-779-1300

PERMIT NUMBER: 11 304564

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Two

<b>Total Glazed Area</b> Minimum 5 Square Feet	6.7 sq. ft.	<b>Difference from Required Area</b>	+1.0 sq.ft.
<b>Width of Opening</b> Minimum 20 Inches	22"	<b>Difference from Required Opening</b>	+ 2"
<b>Height of Opening</b> Minimum 24 Inches	20"	<b>Difference from Required Opening</b>	- 4"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK	<b>Difference from Maximum Height</b>	

COMMENTS:

Reviewed by: David Nelson