



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 11, 2011

Michael McMahon  
11040 Pawnee Ave N  
Stillwater, MN 55082

Re: Appeal for property at 1661 Hubbard Avenue  
File ID: ALH 11-330

Dear Mr. McMahon:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 6.5-inch variance on the openable height of the egress bedroom window measuring 17.5 inches high by 23.5 inches wide.

If you have further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
File

