

OtherOther

# **APPLICATION FOR APPEAL**

RECEIVED
JUN 1 4 2011
CITY CLERK

## Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

ocess your appeal: Saint Paul ter which le	YOUR HEARING Date and Time:  Tuesday, June 28, 2011  Time
Number & Street: 583 Fairview Ave S. City: 57 paul State: MN Zip: 55116	
Tao	Email Hong Cail & Juno. com
	51-199-4590 Cell 651-263-7183
	Date: 6/12/11
Residence	Cell
d and why?	Attachments Are Acceptable
blaces was	1 1 1
- 7 Dove	Ln
Worth Ocles	MN 55127
	-
Second floor-	- Double hung Window (Deficiency list.
	Saint Paul ter which le  ed:  view Ave S. City:  Cao  Residence  Residence  And why?  Please man  7 Dove  North Ocks



CITY OF SAINT PAUL Christopher B. Coleman, Mayor 375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

June 8, 2011

HONG CAO 7 DOVE LANE NORTH OAKS MN 55127-2508

#### FIRE INSPECTION CORRECTION NOTICE

RE:

583 FAIRVIEW AVE S

Ref. #116008

Residential Class: C

### Dear Property Representative:

Your building was inspected on June 8, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A reinspection will be made on July 6, 2011 at 11:15 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

- 1. Bathroom SPLC 34.10 (7), 34.33 (6) Repair and maintain the walls in an approved manner.-Repair or replace the damaged or deteriorated wall coverings.
- 2. Front door SPLC 34.09 (3) i Provide and maintain an approved one-inch throw single cylinder deadbolt lock.

- 3. Second floor Double hung window MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-21h x 31 w Glazed 8.0 sq ft
- 4. Second floor SPLC 34.09 (3), 34.32 (3) Repair and maintain the window glass.
- 5. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 6. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector