



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

FEB 07 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>Feb. 21, 2012</u>
Time: <u>1:30 p.m.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

E-mailed 2-7-12

Address Being Appealed:

Number & Street: 2053 Palace Ave City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Carol Engel

Address (if not Appellant's): 2053 Palace Ave

Phone Numbers: Business _____ Residence 651-699-9026 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing two double hung replacements that do not comply w/ Egress. Openable height 17" on both. One is located in an "office" not currently being used as a bedroom. H/o wants both to match, both located on side of home next to each other.

Please Approve.

WS & D Permit Service
 9533 - 367th Street
 North Branch, MN 55056



**CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM**

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 1, 2012

APPEAL PROPERTY ADDRESS: 2053 PALACE AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 016874

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	8.5	Difference from Required Area	+3.5
Width of Opening Minimum 20 Inches	36"	Difference from Required Opening	+16"
Height of Opening Minimum 24 Inches	17"	Difference from Required Opening	-7"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	OK

COMMENTS: N/A

Reviewed by: J Hoffman 2-1-12



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 1, 2012

APPEAL PROPERTY ADDRESS: 2053 PALACE AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 016874

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	5.6	Difference from Required Area	+.6
Width of Opening Minimum 20 Inches	24"	Difference from Required Opening	+4"
Height of Opening Minimum 24 Inches	17"	Difference from Required Opening	-7"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 2-1-12