



# APPLICATION FOR APPEAL

RECEIVED  
OCT 24 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 11-1-11

Time 1:30

**Location of Hearing:**

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1336 Hartford Ave city: St Paul State: MN Zip: 55116

Appellant/Applicant: Adaptable Builders (Julie Dale) Email \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 612-655-4450

Signature: Julie Dale Date: 10/24/11

Name of Owner (if other than Appellant): Cami Snow

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business 651-310-5040 Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Variance in Egress code  
Call Steve Uhl with questions,  
I am acting like a advocate for  
homeowner



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 4, 2011

APPEAL PROPERTY ADDRESS: 1336 HARTFORD AVE

APPLICANT NAME: ADAPTABLE BUILDERS

PHONE NUMBER: 612-655-4450

PERMIT NUMBER: 11 127808

TYPE OF WINDOW

NUMBER OF WINDOWS

Total Glazed Area Minimum 5 Square Feet	5.1 sq. ft.	Difference from Required Area	Ok
Width of Opening Minimum 20 Inches	22.5"	Difference from Required Opening	Ok

<b>Height of Opening</b>  Minimum 24 Inches	16.5"	<b>Difference from Required Opening</b>	-7.5"
<b>Height of Opening to Finished Floor</b>  Maximum 48 Inches for Existing Openings		<b>Difference from Maximum Height</b>	ok

COMMENTS:

Reviewed by: David Tank