

Inspection Type:

Communicator Test

Electro Watchman Inc.

One West Water Street

Suite # 110

St. Paul, MN 55107

651-227-8461 / 1-800-223-8599

Minnesota State License # TS00224

Inspections:

NFPA 72 Ed. _____

NFPA 70 Ed. _____

NFPA 101 Ed. _____

Account #: _____ Local _____

Second Monitoring _____

Account #: _____

Entry Info: _____

Inspection and Testing Form

Protected Property:

Kruchowski Bldg, Caryl

598 Grand Ave.

St. Paul, MN 55102

Contact: Caryl Kruchowski

Phone: 612-451-5320

Responding Fire Department:

St. Paul Fire Department

100 11th Street East

St. Paul, MN 55101

Contact: Tim Butler

Phone: 651-224-7811

Signed: Dr. SwengelTime in: 1500Time Out: 1600Date: 5-5-17Pass: es

Fail: _____

Monitoring Agency:

Electro Watchman Inc.

One West Water Street

Suite # 110

St. Paul, MN 55107

Contact: Jenny Garza

Phone: 651-227-8461

Second Monitoring Agency:

Customer Signature: _____

Inspection Comments:

System Devices:

Water Flow: _____

Wet: _____

Dry: _____

Tamper _____

Switches: _____

WPIV: _____

PIV: _____

Room Temp: _____

Water Temp: _____

Hi/Lo Air: _____

Smoke _____

Ion: _____

Detectors: 5

Photo: 5

w/Heat: 5

Heat _____

Fixed: _____

135: _____

190: _____

Detectors: _____

RoR: _____

135: _____

190: _____

Manual: _____

Duct _____

Ion: _____

Remote _____

Detectors: _____

Photo: _____

Test: _____

Horns: 3

Strobes: _____

Horn/Strobes: _____

Annunciators: _____

Other: _____

System Battery:

Type: Sealed Lead-Acid

MIN AH: 8

Qty: 2

Calculated Time: 24/5

AH USED: 8

MoH's: _____

Primary Power: _____

Panel: H

Breaker: 2

Point #:
NA

Type: _____ MIN AH: _____ Qty: _____
Calculated Time: _____ AH USED: _____ MoH's: _____
Primary Power: _____ Panel: _____ Breaker: _____

[illegible]