



APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED

310 City Hall, 15 W. Kellogg Blvd.

JUN 05 2012

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

CITY CLERK

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 6-19-12

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 806-808 Como City: St. Paul State: Mn Zip: 55102

Appellant/Applicant: Allan G. Petersen Email: archaicfurniture@comcast.net

Phone Numbers: Business _____ Residence _____ Cell 651 329-7157

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Allan Petersen

Address (if not Appellant's): 8625 Kimbro Ln - Stillwater Mn

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other _____

I wasn't informed when I purchased the property, that it needed Egress windows and a driveway.

I would not have purchased this property. ~~It was not~~



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

May 25, 2012

AL PETERSEN
8625 KIMBRO LN
STILLWATER MN 55082-9372

FIRE INSPECTION CORRECTION NOTICE

RE: 806 COMO AVE
Ref. #106304
Residential Class: C

Dear Property Representative:

Your building was inspected on May 25, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on June 28, 2012 at 1:00 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 806 - BEDROOM - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.
-Double Hung
16h x 33w Openable
16h x 31.5w Glazed

2. 806 - BEDROOM - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window in good condition.-Provide a handle.
3. 806 - FRONT DOOR - SPLC 34.09 (3) i - Provide and maintain an approved one-inch throw single cylinder deadbolt lock.-Measured 5/8 of an inch.
4. 806 - GUEST ROOM - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.

-Double Hung
16h x 29w Openable
16h x 27.5w Glazed

5. 808 - BEDROOM - SPLC 34.13 (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the sleeping rooms to:

-Double Hung
16h x 33w Openable
16h x 31.5w Glazed

6. 808 - KITCHEN DOOR - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door in good condition.-Repair the door handle.
7. 808 - THROUGHOUT - MSFC 1003.3.1.8 - Remove unapproved locks from the unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort.-Remove all the chain locks.
8. 808 - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturer's instructions.-Replace the battery.
9. BASEMENT - DRYER - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.
10. BASEMENT - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.-Provide a smoke detector.
11. EXTERIOR - DRIVEWAY - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.

12. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
13. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

St. Paul.gov govt city clerk

If you have any questions, email me at: Sebastian.Migdal@ci.stpaul.mn.us or call me at 651-266-8985 between 8:00 a.m. - 9:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Sebastian Migdal
Fire Inspector

Reference Number 106304