



APPLICATION FOR APPEAL

RECEIVED
JUL 21 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 8-9-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

walk-in

Address Being Appealed:

Number & Street: 1804 Highland PKWY City: Sf. Paul State: MN Zip: 55116

Appellant/Applicant: Jeff Moore - Capital Siding Windows + Const. Email: capitalsidingwindows2comcast.net

Phone Numbers: Business 651-578-9205 Residence _____ Cell 651-248-7227

Signature: Sheila Moore Date: 7-21-11

Name of Owner (if other than Appellant): Robert + Mary Kuhl

Address (if not Appellant's): Same

Phone Numbers: Business _____ Residence _____ Cell 651-283-2597

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: July 21, 2011

APPEAL PROPERTY ADDRESS: 1804 HIGHLAND PKWY
APPLICANT NAME: CAPITAL SIDING & WINDOWS
PHONE NUMBER: 612-578-9205
PERMIT NUMBER: 11 253438
TYPE OF WINDOW 2
NUMBER OF WINDOWS Double hung

Total Glazed Area Minimum 5 Square Feet	7.3 sq. ft.	Difference from Required Area	+2.3 sq. ft.
Width of Opening Minimum 20 Inches	26.375"	Difference from Required Opening	+6.375"
Height of Opening Minimum 24 Inches	19.9375"	Difference from Required Opening	-4.0625"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS: Based on information provided above determination to be made by legislative hearing officer.

Reviewed by: DD 7-21-11