


# APPLICATION FOR APPEAL

Saint Paul City Clerk  
 310 City Hall, 15 W. Kellogg Blvd.  
 Saint Paul, Minnesota 55102  
 Telephone: (651) 266-8560



The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday, 12/14/10	
Time	1:30
Location of Hearing:	
Room 330 City Hall/Courthouse	

Arrived 12/16/10

## Address Being Appealed:

Number & Street: 927 Tuscarora Ave St. Paul  
 City: St. Paul State: MN Zip: 55103

Appellant/Applicant: John W. Taylor  
 Email: JohnWTaylor3@gmail.com  
 Phone Numbers: Business: 651-6875020  
 Residence: ~~612-578-6024~~ Cell: 612-578-6024  
 Name: ~~John W. Taylor~~ *John W. Taylor*

Signature: *John W. Taylor*  
 Date: 12-3-10

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business: \_\_\_\_\_ Residence: \_\_\_\_\_ Cell: \_\_\_\_\_

## What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

#12 on list of attached list.  
 - The existing windows are close to code. Replacement would be difficult and costly.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

November 17, 2010

JOHN W TAYLOR III  
BARBARA TAYLOR  
3625 47TH ST EAST  
MINNEAPOLIS MN 55406-3866

**FIRE INSPECTION CORRECTION NOTICE**

RE: 927 TUSCARORA AVE  
Ref. #102326  
Residential Class: C

Dear Property Representative:

Your building was inspected on November 16, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on December 20, 2010 at 1:00 PM.  
Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

**DEFICIENCY LIST**

1. Attic - SPLC 34.23, MSFC 110.1 - This attic is condemned as a sleeping area. This attic must not be used as a sleeping area until re-inspected and approved by this office.- Remove beds from the attic.
2. Basement - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be a minimum nominal size of four inches (102 mm) in diameter. The exhaust duct shall be constructed of metal and shall have a smooth interior finish. This work may require a permit(s). Call DSI at (651) 266-8989.
3. Basement - MSFC 605.1 - Provide a grounding jumper around the water meter. An Equal Opportunity Employer

DEPARTMENT OF SAFETY AND INSPECTIONS  
Fire Inspection Division  
Ricardo X. Cervantes, Director

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.sipaul.gov/dsi](http://www.sipaul.gov/dsi)