



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

June 29, 2015

Fire Report

812 Cook Ave. E.

Details: Fire on east side of house burnet up outside of house and in to sofit and into roof system ,all truss rafters where damaged and need replacement . Common rafters are ok but need some clean up and sealer.

House type: 1 1/2 story CMU foundation with basement.

Construction type: VB

Structural damage: roof rafters and wall and roof sheathing.

Building systems affected: Electrical, Plumbing, Warm Air and Mechanical permits required

- Remove all fire and water damaged materials, wash and seal exposed surfaces.
- Insulate exposed open exterior walls and ceilings and provide vapor barrier.
- Replace wood doors and trim, install kitchen cabinets.
- Repair/replace damaged window sash and storm windows, and replace broken glazing.
- Prepare, prime and paint paintable surfaces, stain and finish wood doors and wood trim.
- Install underlayment where necessary, and replace floor coverings.
- Install smoke detectors per state code. Detectors must be interconnected and hardwired in basement due to ceiling finish being removed.
- Provide an attic access with a framed opening not less than 22 x 30 inches in a hallway or other readily accessible location.
- Replace damaged siding ,trim ,sofit, sheathing and roofing as needed for east and upper part of house, call for required inspections.

James Seeger
Building Inspector

An Equal Opportunity Employer