



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 11, 2011

Bryan Horton
Renewal by Andersen Corporation
obo Jennifer Davis-Lammers
1920 County Rd C W
Roseville MN 55113

VIA EMAIL: bryan.horton@andersencorp.com

Re: Appeal for property at 426 Mt Curve Rd
File ID: ALH 11-303

Dear Mr. Horton:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 3 1/8-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 20 7/8 inches high by 20 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
File

