



# APPLICATION FOR APPEAL

RECEIVED  
JUN 22 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed *mailed*

YOUR HEARING Date and Time:

Tuesday, 7-10-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1839 WELLESLEY City: ST. PAUL State: MN Zip: 55105

Appellant/Applicant: HARMONY HOMES INC Email C.McGRATH@HarmonyHomesInc.NET

Phone Numbers: Business 763.413.1100 Residence \_\_\_\_\_ Cell 612 655 5234

Signature: C.McGrath CHRIS McGRATH Date: \_\_\_\_\_

Name of Owner (if other than Appellant): RODNEY MORE

Address (if not Appellant's): 1839 WELLESLEY

Phone Numbers: Business \_\_\_\_\_ Residence 651.690.4396 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

PERMIT TO INSTALL 3 BEDROOM WINDOWS,  
ALL ARE THE LARGEST INSERT AVAILABLE  
TO MATCH EXISTING, BUT DO NOT MEET  
EGGRESS CODE FOR ST. PAUL. THEY DO  
COMPLY WITH MN BUILDING CODE R310.1.5

THANK YOU



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 14, 2012

APPEAL PROPERTY ADDRESS: 1839 WELLESLEY AVE  
APPLICANT NAME: HARMONY HOMES INC  
PHONE NUMBER: 612-238-0527  
PERMIT NUMBER: 12 069026  
TYPE OF WINDOW Double Hung  
NUMBER OF WINDOWS 3

<b>Total Glazed Area</b> Minimum 5 Square Feet	4.4	<b>Difference from Required Area</b>	-6
<b>Width of Opening</b> Minimum 20 Inches	29	<b>Difference from Required Opening</b>	+9
<b>Height of Opening</b> Minimum 24 Inches	19 ¾	<b>Difference from Required Opening</b>	-4 ¼
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	ok

COMMENTS: N/A

Reviewed by: J Hoffman 6/14/12