



APPLICATION FOR APPEAL

RECEIVED
JUN 20 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>7-10-12</u>
Time <u>1:30 P.M.</u>
Location of Hearing: <u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1361 Kenneth St City: St. Paul State: MP Zip: _____

Appellant/Applicant: St. Croix Home Improvement Email dc.maddux@comcast.net

Phone Numbers: Business 651-775-5088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Brian Morris @ Cari Dwyer

Address (if not Appellant's): 1361 Kenneth St.

Phone Numbers: Business 612 Residence _____ Cell 612-384-1596

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other Egress window non-compliance
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 25, 2012

APPEAL PROPERTY ADDRESS: 1361 KENNETH ST

APPLICANT NAME: ST CROIX HOME IMPROVEMENT INC

PHONE NUMBER: 651-775-5088

PERMIT NUMBER: 12 073450

TYPE OF WINDOW CASEMENT

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	5.86 SQ. FT	Difference from Required Area	+ .86 SQ. FT.
Width of Opening Minimum 20 Inches	17.625"	Difference from Required Opening	-2.375"
Height of Opening Minimum 24 Inches	50"	Difference from Required Opening	+26"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS:

Reviewed by: DD 6-25-12