



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

APR 11 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
 Tuesday, April 17, 2012
 Time 1:30 p.m.
 Location of Hearing:
 Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1176 Supornick LN City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Tony Swanson Email anthony.swanson@stpha.org

Phone Numbers: Business 651-298-4907 Residence _____ Cell _____

Signature: [Handwritten Signature] Date: 4-11-12

Name of Owner (if other than Appellant): Public Housing Agency of St. Paul

Address (if not Appellant's): 555 N. Wabasha Suite # 400 St. Paul, MN 55102

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#6 A and B All Bedrooms - MSFC 1026.1
Request Variance on openable height

C: J. MACDONALD
B. SHERRY
T. SWANSON

DEPARTMENT OF SAFETY AND INSPECTIONS
Fire Inspection Division
Ricardo A. Cervantes, Director




CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 4, 2012

BETTYLOU AUTHIER
PUBLIC HOUSING AGENCY
200 ARCH ST E
ST PAUL MN 55130-4347



FIRE INSPECTION CORRECTION NOTICE

RE: 1176 SUPORNICK LANE
Ref. #111602
Residential Class: C

Dear Property Representative:

Your building was inspected on April 3, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on April 27, 2012 at 10:00A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. **J. MACDONALD - WO# 5000343**
A - MSFC 901.8.1 - It shall be unlawful for any person to remove, tamper with or otherwise disturb or cover detectors with plastic.
2. **B. SHERRY - WO# 5000344**
A - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water. After securing toilet to floor caulk the base.
3. **J. MACDONALD - WO# 5000347**
A - MSFC 315.2.5 - Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equipment and portable cooking equipment, shall not be stored, operator or repaired within a building.-remove from basement at time of inspection

A CHAIRMAN GRILL

An Equal Opportunity Employer

J. MACDONALD - W0#5000347

4. A - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials. -Gas can removed at time of inspection

B. SHERRY - W0#5000344

5. A - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition. -Repair or replace and maintain an approved private toilet. Secure toilet to floor.

B. SHERRY / T. SWANSON - W0#5000345 (B) W0#5000346

6. A and B All Bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266- 9090. Refer to the Escape Windows for Residential Occupancies handout for more information. -Double hung widows. 18inches openable height . Openable width 32inches. Sill is 39inches. Glazed is 36inches in height by 38inches in width.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 111602