



APPLICATION FOR APPEAL

RECEIVED

JUL 25 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 8-16-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1381 HAZELWOOD ST City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: MICHAEL TAFF Email MICHAEL.TAFF@US.ARMY.MIL

Phone Numbers: Business 282-4627 (651) Residence 651-450-2357 Cell 952-237-7902

Signature: [Signature] Date: 25 JUL 11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 9237 CHENEY TRAIL, INVERGROVE HEIGHTS, MN 55076

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

HOME WAS PURCHASED IN 2000. WINDOWS WERE INSTALLED.

HOUSE IS STUCCO AND REPLACING ALL

WINDOWS WOULD CAUSE SEVERE FINANCIAL

HARDSHIP.

*DOUBLE HUNG WINDOWS HAVE BOTH
PANES REMOVABLE. CASEMENT AS WELL

Revised 4/22/2011



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 18, 2011

MICHAEL TAFF
9237 CHENEY TR
INV GRV HGTS MN 55076-3536

FIRE INSPECTION CORRECTION NOTICE

RE: 1381 HAZELWOOD ST
Ref. #106253
Residential Class: B

Dear Property Representative:

Your building was inspected on July 18, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on August 18, 2011 at 10:00 A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. BEHIND DRYER - MSFC 1303 - Maintain accumulations of dust to a minimum. Floors and other surface dust must be collected by vacuum cleaning. Force air must not be used.
2. Downstairs - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Windows measured at 14inches in openable height with 29inches in width. Sill is 44inches. Glazed is 28inches in height by 25inches in width. These are double hung windows.

An Equal Opportunity Employer

3. Upstairs - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.-Remove charcoal and lighter fluid from kitchen.
4. Upstairs - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Windows measured at 18inches openable width and a Sill of 44inches . Openable height is 32inches. Glazed measurements are 28inches in height by 18inches in width. These are casement windows.
5. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work WILL require a permit(s). Call DSI at (651) 266-8989.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 106253