

RECEIVED
OCT 25 2010
CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, NOV 2

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1580 McLean Ave City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Renewal by Andersen Email: bryan.horton@andersenacorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): John and Denise Kniprath

Address (if not Appellant's): 1580 McLean Ave

Phone Numbers: Business _____ Residence 651-772-1040 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 bedroom windows that will not comply w/ St. Paul Egress Policy. Windows will have a opening height of 18" and will have a opening width of 40". Homeowner wants to keep existing style. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 21, 2010

APPEAL PROPERTY ADDRESS: 1580 MCLEAN AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 913112
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 3

Total Glazed Area	11.8 sq. ft.	Difference from Required Area	+ 6.8 sq. ft.
Width of Opening	40"	Difference from Required Opening	+ 20"
Height of Opening	18"	Difference from Required Opening	- 6"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.