

✓ scanned



# APPLICATION FOR APPEAL

RECEIVED  
JAN 10 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>1-18-2011</u>
Time <u>1:30</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 1401 Arundel City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Appellant/Applicant: Window World-Esther Dahl Email estherd@windowworldmn.com

Phone Numbers: Business 651-770-9315 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: Esther Dahl Date: 1/6/11

Name of Owner (if other than Appellant): Rosie Strehben

Address (if not Appellant's): 1401 Arundel

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O \_\_\_\_\_
- Summary/Vehicle Abatement \_\_\_\_\_
- Fire C of O Deficiency List \_\_\_\_\_
- Fire C of O: Only Egress Windows \_\_\_\_\_
- Code Enforcement Correction Notice \_\_\_\_\_
- Vacant Building Registration \_\_\_\_\_
- Other Asking for Variance on windows, we exceed 3 out of 4 requirements
- Other \_\_\_\_\_
- Other \_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: December 15, 2010

APPEAL PROPERTY ADDRESS: 1401 ARUNDEL ST

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 604839

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 bedrooms

<b>Total Glazed Area</b>	1. 8 sq ft 2. 8sq ft	<b>Difference from Required Area</b>	1. +3 sq ft ok 2. +3 sq ft ok
<b>Width of Opening</b>	1. 28.5" 2. 28.5"	<b>Difference from Required Opening</b>	1. +8.5" 2. +8.5"
<b>Height of Opening</b>	1.. 20" 2. 20"	<b>Difference from Required Opening</b>	1. -4' 2. -4'
<b>Height of Opening to Finished Floor</b>	1. 28" 2. 28"	<b>Difference from Maximum Height</b>	1. +20" ok 2. +20" ok

COMMENTS: Need smoke detector in basement.

Reviewed by: David Tank

**Select a Model**

<b>(Model 0201)</b>	
0201 ▼	
<b>Excalibur Double Hung</b>	
<b>Top Sash Width</b>	<b>28.3750</b>
<b>Top Sash Height</b>	<b>25.1250</b>
<b>Bottom Sash Width</b>	<b>29.3750</b>
<b>Bottom Sash Height</b>	<b>26.1250</b>
<b>Top Glass Width</b>	<b>26.6875</b>
<b>Top Glass Height</b>	<b>23.4375</b>
<b>Bottom Glass Width</b>	<b>27.6875</b>
<b>Bottom Glass Height</b>	<b>24.4375</b>
<b>Screen Width</b>	<b>27.9375</b>
<b>Screen Height</b>	<b>26.3750</b>
<b>Top Sash Weight (Plus 5 lb)</b>	<b>22 lb</b>
<b>Top Balance Size (C.F)</b>	<b>56BU</b>
<b>Top Balance Size (Spiral)</b>	<b>21-8B</b>
<b>Bottom Sash Weight</b>	<b>19 lb</b>
<b>Bottom Balance Size (C.F)</b>	<b>55RD</b>
<b>Bottom Balance Size (Spiral)</b>	<b>25-7R</b>
<b>Egress Opening Width</b>	<b>27.2190</b>
<b>Egress Opening Height</b>	<b>19.9375</b>
<b>Egress Opening Area (sq.ft.)</b>	<b>3.7690</b>

<b>Min. W: 11</b>	<b>Max W: 52</b>		
<b>Min. H: 20</b>	<b>Max H: 84</b>		
<b>Max UI: 132</b>			
<b>Exact Size</b>			
Width:	<table border="1"> <tr> <td><b>31 5/8</b></td> <td><b>31.625</b></td> </tr> </table>	<b>31 5/8</b>	<b>31.625</b>
<b>31 5/8</b>	<b>31.625</b>		
Height:	<table border="1"> <tr> <td><b>53 3/8</b></td> <td><b>53.375</b></td> </tr> </table>	<b>53 3/8</b>	<b>53.375</b>
<b>53 3/8</b>	<b>53.375</b>		
Extrusion:	Select Extrusion ▼ << For Arch-Top Models Only		
Opening:	Exact Size ▼		
Type:	Standard ▼		
Screen:	Half ▼		
Glass:	Double Strength (3 mm) ▼		

 AC Sash Calculator