



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8585 FAX: (651) 266-8574

July 12, 2013

Bee Vang  
970 Margaret Street  
Saint Paul MN 55117

VIA EMAIL: [peteryang05@yahoo.com](mailto:peteryang05@yahoo.com)

Re: Appeal for property at 970 Margaret Street

Dear Mr. Nelson:

This is to confirm that on July 9, 2013 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended that the City Council deny your appeal relating to providing a window in the bathroom with an aggregate glazing area of not less than 3 sq ft and one-half of which must be openable or installing an exhaust system vented to the outside.

If you wish to contest further, the matter is scheduled for City Council Public Hearing on Wednesday, July 24, 2013 at 5:30 p.m. in Room 300 Council Chambers.

Any questions, you may contact me at 651-266-8563.

Sincerely,  
/s/

Mai Vang

c: Stephen Ubl (email)  
Jim Seeger (email)

