



APPLICATION FOR APPEAL

RECEIVED
AUG 26 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 9-13-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Home Depot Contact:
Dave Olson 763-213-3611

Number & Street: 1191 Fairmount Ave, City: St. Paul State: MN Zip: 55105

Appellant/Applicant: _____ THD At-Home Service, Inc, il _____
2690 Cumberland Pkwy, Ste 300

Phone Numbers: Business _____ Atlanta, GA 30339-3913 _____ Cell _____
Lic # 20268257 Ph. 763/542-8826

Signature: _____ Date: _____

Name of Owner (if other than Appellant): Robin Fate

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence 651/431-8846 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 24, 2011

APPEAL PROPERTY ADDRESS: 1191 FAIRMOUNT AVE

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 770-779-1300

PERMIT NUMBER: 11 267344

TYPE OF WINDOW double hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	5.45 sq. ft.	Difference from Required Area	-.25 sq. ft.
Width of Opening Minimum 20 Inches	24.5"	Difference from Required Opening	+4.5"
Height of Opening Minimum 24 Inches	19"	Difference from Required Opening	-5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 8-24-11