



APPLICATION FOR APPEAL

RECEIVED

DEC 06 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/14/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2099 Suburban Ave City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Martha Forrest

Address (if not Appellant's): 2099 Suburban Ave

Phone Numbers: Business _____ Residence 651-755-5874 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement double hung that will not comply w/ Egress policy. The homeowner has Double hung style throughout the house and wants style to stay consistent. Width and overall glazed area are met or exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

RECEIVED
DEC 06 2010
CITY CLERK

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 2, 2010

APPEAL PROPERTY ADDRESS: 2099 SUBURBAN AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 929068
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 1

Total Glazed Area	8.7 sq. ft.	Difference from Required Area	+ 3.7 sq. ft.
Width of Opening	20"	Difference from Required Opening	---
Height of Opening	18 3/4"	Difference from Required Opening	- 5 1/4"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B. H.