



APPLICATION FOR APPEAL

RECEIVED
OCT 25 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>11-8-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

WALK-IN

Address Being Appealed:

Number & Street: 1403 Schaffer Ave City: St. Paul State: Mn Zip: 55116

Appellant/Applicant: Bob Shackelford Email _____

Phone Numbers: Business _____ Residence _____ Cell 612 245 3232

Signature: *[Signature]* Date: 10/25/11

Name of Owner (if other than Appellant): John Wolline

Address (if not Appellant's): 1403 Schaffer Ave

Phone Numbers: Business _____ Residence 651-699-4624 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows Brick exterior
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/25/11

APPEAL PROPERTY ADDRESS: 1403 Scheffer Ave ~

APPLICANT NAME: Bob Shackelford PHONE NUMBER: 612 245 3232

PERMIT NUMBER: 11-290557

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 11.6 Sq. Ft DIFFERENCE FROM REQUIRED AREA: +6.6

WIDTH OF OPENING: 40 1/16" DIFFERENCE FROM REQUIRED OPENING: +20 1/16"

HEIGHT OF OPENING: 23" DIFFERENCE FROM REQUIRED OPENING: -1.

HEIGHT OF OPENING TO FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: OK

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/25/2011

APPEAL PROPERTY ADDRESS: 1403 Scheffer Ave, 55116

APPLICANT NAME: Bob Shackelford PHONE NUMBER: 612-245-3232

PERMIT NUMBER: 11-290557

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.5 sq ft

DIFFERENCE FROM REQUIRED AREA: + 3.5 sq ft

WIDTH OF OPENING: 30 1/16

DIFFERENCE FROM REQUIRED OPENING: + 10 1/16

HEIGHT OF OPENING: 23

DIFFERENCE FROM REQUIRED OPENING: - 1

HEIGHT OF OPENING TO FINISHED FLOOR: < 48

DIFFERENCE FROM MAXIMUM HEIGHT: OK

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/25/2011

APPEAL PROPERTY ADDRESS: 1403 Scheffer Ave, 55116

APPLICANT NAME: Bob Shackelford PHONE NUMBER: 612-245-3232

PERMIT NUMBER: 11-290557

TYPE OF WINDOW: Double Casement

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.48 sq ft DIFFERENCE FROM REQUIRED AREA: + 3.48 sq ft

WIDTH OF OPENING: 13.423 DIFFERENCE FROM REQUIRED OPENING: -6.577

HEIGHT OF OPENING: 32.9 DIFFERENCE FROM REQUIRED OPENING: + 8.9

HEIGHT OF OPENING TO FINISHED FLOOR: < 48 DIFFERENCE FROM MAXIMUM HEIGHT: OK

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____