



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

AUG 03 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 8-23-11

Time 1:30

Location of Hearing:


Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1871 Conway St City: St-Paul State: MN Zip: 55119

Appellant/Applicant: Raymond S. Simpson Email: Raysimpson5@hotmail.com

Phone Numbers: Business 651-486-9404 Residence _____ Cell 651-983-9404

Signature:  Date: 8/2/11

Name of Owner (if other than Appellant): S/A

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Bedroom window is 6 ft² glazed area. Openable width is 23", Height is 22". I am requesting a waiver for this window.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 29, 2011

RAYMOND J SIMPSON
3624 GROVNER RD N
OAKDALE MN 55128-3219

FIRE INSPECTION CORRECTION NOTICE

RE: 1871 CONWAY ST
Ref. #117128
Residential Class: A

Dear Property Representative: There will be no need for a reinspection as long as the information of appeal for windows and the permits needed to install heating unit .

Your building was inspected on July 29, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
2. MN Rules 1300.0180 - Immediately discontinue use of unsafe heating appliance until repaired or replaced by a licensed contractor. This work may require a permit(s). Call DSI at (651) 266-9090. Red tags may not be removed except by fire department inspector.

3. MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung windows. Openable height is 22inches and the openable width is 23inches . Sill is 27inches. Glazed 44inches height by 20inches in width.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 117128