

APPLICATION FOR APPEAL

Saint Paul City Council - Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

AUG 08 2013

CITY CLERK



We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders/letter being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

Address Being Appealed:

Number & Street: 1447 White Bear Ave. City: St. Paul State: MN Zip: 55106
 Appellant/Applicant: Julie Peterson Email: peju0302@hotmail.com
 Phone Numbers: Business: _____ Residence: _____ Cell: 651-278-8795

Signature: *Julie Peterson*
 Name of Owner (if other than Appellant): _____
 Mailing Address if Not Appellant's: _____
 Phone Numbers: Business: _____ Residence: _____ Cell: _____

What Is Being Appealed and Why? Attachments Are Acceptable

We have an older house and would like our upper bedroom window dimensions to be accepted so that foster care children may occupy those rooms. Currently, they are 19" high by 24" wide.
 Thank you.

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

HEARING DATE & TIME	
(provided by Legislative Hearing Office)	Tuesday, <i>Aug 20, 2013</i>
Time	<i>1:30 pm</i>
Location of Hearing:	Room 330 City Hall/Courthouse



July 26, 2013

JULIE PETERSON & SARA RUHRW
1447 WHITE BEAR AVE
ST PAUL MN 55106

CORRECTION NOTICE – FOSTER CARE INSPECTION

RE: 1447 WHITE BEAR AVE N

Dear Property Representative:

An inspection was made of your building on July 25, 2013 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately. A re-inspection will be made on August 22, 2013 at 10:00AM.

DEFICIENCY LIST

1. ANNUAL FURNACE MAINTENANCE - PROVIDE DOCUMENTATION - SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
2. DRYER VENT - PROVIDE APPROVED EXHAUST DUCT - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.-Replace the flex dryer vent with materials as describe above.
3. UPPER BEDROOMS - WINDOW OPENABLE DIMENTIONS - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.*The upper eastside bedroom has original windows with openable dimensions of 19 inches high by 24 inches wide X two windows. The upper southside bedroom also has original windows with openable dimensions of 19 inches high by 24 inches wide X two windows.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/coro>

*You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: james.perucca@ci.stpaul.mn.us or call me at 651-266-8996 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Perucca
Fire Inspector

JULIE PETERSON & SARA RUHROW

1447 WHITE BEAR AVE

ST PAUL MN 55106

CORRECTION NOTICE – FOSTER CARE INSPECTION

RE: 1447 WHITE BEAR AVE N

Dear Property Representative:

An inspection was made of your building on July 25, 2013 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately. A re-inspection will be made on August 22, 2013 at 10:00AM.

DEFICIENCY LIST

1. ANNUAL FURNACE MAINTENANCE - PROVIDE DOCUMENTATION - SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

2. DRYER VENT - PROVIDE APPROVED EXHAUST DUCT - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth

interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.-Replace the flex dryer vent with materials as describe above.

3.

UPPER BEDROOMS - WINDOW OPENABLE DIMENTIONS - MSFC1026.1 - Provide and maintain an

approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-*The upper eastside bedroom has original windows with openable dimensions of 19 inches high by 24 inches wide X two windows. The upper southside bedroom also has original windows with openable dimensions of 19 inches high by 24 inches wide X two windows.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

*You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: james.perucca@ci.stpaul.mn.us or call me at 651-266-8996

between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Perucca

Fire Inspector