



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Jeff Beissel
Beissel Window and Siding, Co.
1635 Oakdale Ave
West St. Paul, MN 55118

VIA EMAIL: jeff@beisselwindows.com

Re: Appeal for property at 1807 Stillwater Avenue East.
File ID: ALH 10-296

Dear Mr. Beissel:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 5.12-inch variance on the openable height of twenty-three (23) double hung replacement egress bedroom windows measuring 18.87 inches high by 35 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Paralegal

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Boom (email)
Ryan Rehn (email)
Stephen Ubl (email)

