



APPLICATION FOR APPEAL

RECEIVED

FEB 15 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Feb. 21, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

in person

Address Being Appealed:

Number & Street: 1200 Carpentier AVE City: St Paul State: MN Zip: _____

Appellant/Applicant: The Window Store Home Emp Email Michelle @homesure inc.com

Phone Numbers: Business 612 353-5780 Residence _____ Cell _____

Signature: Deak Tanberg Date: 2-15-12
Tanberg
604 1/2 Central Ave
Fridley, MN 55422

Name of Owner (if other than Appellant): Larry Sklaney

Address (if not Appellant's): 1200 Carpentier AVE St Paul

Phone Numbers: Business _____ Residence 612 785-4954 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List
 - Fire C of O: Only Egress Windows
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other
 - Other
 - Other
- needs DH windows ~~for the units~~
to match the rest of the house



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 30, 2012

APPEAL PROPERTY ADDRESS: 1200 LARPEN TEUR AVE E
APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC
PHONE NUMBER: 612-353-5780
PERMIT NUMBER: 12 014462
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	4.909 sq. ft.	Difference from Required Area	-.791 sq. ft.
Width of Opening Minimum 20 Inches	35.344"	Difference from Required Opening	+15.344"
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 1-30-12