

Vang, Mai (CI-StPaul)

From: Vang, Mai (CI-StPaul)
Sent: Wednesday, April 08, 2015 2:25 PM
To: mcpotter@cbburnet.com
Cc: 'Huseby, Laura (CI-StPaul)'; Neis, Adrian (CI-StPaul); Owens, Phil (CI-StPaul); Shaff, Leanna (CI-StPaul)
Subject: 1656 Craig Place appeal

Hello Mr. Potter,

The above matter was heard on March 24 and Ms. Moermond stated she would need to check on whether there was a bldg. permit pulled for the basement remodel. On March 26, Supervisor Neis stated that he and Inspector Huseby looked through the paper file and did not find any building permit(s). Therefore, Ms. Moermond is recommending that the City Council deny a variance on the electrical panel issue. The wall has been moved so it will need to be fixed under permit with at least 36 inches clearance.

If you wish to appeal further, you may attend the City Council Public Hearing on Wednesday, May 6, 2015 at 5:30 p.m. in Rm 300 Council Chambers.

Mai Vang



Coordinator for Legislative Hearings
City Council Offices
15 W. Kellogg Blvd, Ste. 310
Saint Paul, MN 55102
Direct: 651-266-8563
Appeals Line: 651-266-8585
Fax: 651-266-8574

mai.vang@ci.stpaul.mn.us

The Most Livable
City in America

