



APPLICATION FOR APPEAL

RECEIVED
AUG 29 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 517067)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
 Tuesday, Sept. 13, 2011
 Time 1:30 p.m.
 Location of Hearing:
 Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1152 ROSE AVE E City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: MARK MASON Email mark.mason@mason-vei.com

Phone Numbers: Business _____ Residence _____ Cell 651-335-2610

Signature: [Signature] Date: 8-29-11

Name of Owner (if other than Appellant): SOLD HOME TO NEW OWNER -

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

CAT a BUILDING - Replaced two old windows with largest possible w/o opening walls & re-framing. Made windows bigger than before. Also contractor who is long gone did not do any of this so now I'm picking up the pieces



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 17, 2011

APPEAL PROPERTY ADDRESS: 1152 ROSE AVE E

APPLICANT NAME: CUTS CUSTOM CONSTRUCTION INC

PHONE NUMBER: 651-578-9210

PERMIT NUMBER: 11 112518

① } 2 windows in
② } same room

TYPE OF WINDOW

NUMBER OF WINDOWS ① 1 Double Hung } OLD WINDOWS WERE BOTH
 ② 1 CRANK OUT } REPLACEMENT DOUBLE HUNG.

Total Glazed Area	① 5.01 5.01	Difference from Required Area	0
Minimum 5 Square Feet	② 5.4		+ .4
Width of Opening	① 19	Difference from Required Opening	1
Minimum 20 Inches	② 17		3

Height of Opening Minimum 24 Inches	① 19 ② 43	Difference from Required Opening	5 + 19
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	① 42" ② 35"	Difference from Maximum Height	— —

COMMENTS: LOCATION: UPPER LEVEL PLAY ROOM / BED ROOM (1.5 STORY HOUSE)
 EXISTING / OLD WINDOW OPENINGS WERE ONLY
 18" X 18" IN BOTH CASES. THE NEW WINDOW INCREASES
 DOUBLE HUNG SPACE AND CRANK OUT MAKES MUCH
 BIGGER OPENING THAT WAS PRESENT.

Reviewed by: