



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

OCT 07 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>Oct. 25, 2011</u>
Time <u>1:30 p.m.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1921 Lincoln Ave City: St Paul State: MN Zip: 55105

Appellant/Applicant: Clarence A Chaplin Email cachaplin@mac.com

Phone Numbers: Business _____ Residence 651-695-0982 Cell 651-402-4601

Signature: C A Chaplin Date: 10/5/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Contractor who installed my windows in Dec 2010 did not pull a permit and did not obtain permission to install same size windows before doing my windows. I just learned today from Ken Eggus when he came to my home to look @ windows, that some of them are in non-compliance.

1921



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10.5.11

APPEAL PROPERTY ADDRESS: 1921 ~~3010~~ Lincoln

APPLICANT NAME: Clarence Chaplin PHONE NUMBER: (651) 695-0982

PERMIT NUMBER: _____

TYPE OF WINDOW: PTH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8' / 5.5' DIFFERENCE FROM REQUIRED AREA: +3' / +.5'
1st flr 2nd flr

WIDTH OF OPENING: 24" / 20.5 DIFFERENCE FROM REQUIRED OPENING: +4 / +.5
1st flr 2nd flr

HEIGHT OF OPENING: 2 1/2' / 17.5 DIFFERENCE FROM REQUIRED OPENING: -2 1/2' / -6.5"

HEIGHT OF OPENING TO FINISHED FLOOR: 37' / 31" DIFFERENCE FROM MAXIMUM HEIGHT: -11" / -17"

COMMENTS: 1st floor Bedrooms & 2nd floor bedrooms (1) only

FROM: Ken Eggen