

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: _____

Cover Sheet and Transmittal Form

FACSIMILE TRANSMISSION

To FAX#: 6-8574

To: Mai Yang, Paralegal

Location: Legislative Hearing Office
City of St Paul

Sender: Daniel Schmidt / Jim Hannareddy
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

1 of 2

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 2/17/11

APPEAL PROPERTY ADDRESS: 1256 RICE ST

APPLICANT NAME: PUBLIC HEALTH - DANIEL SCHMIDT
DANIEL SCHMIDT OF DANVY, MN PHONE NUMBER: 651-266-1143

PERMIT NUMBER:

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 83 sq ft

DIFFERENCE FROM REQUIRED AREA: COMPLES

WIDTH OF OPENING: 23"

DIFFERENCE FROM REQUIRED OPENING: COMPLES

HEIGHT OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING FROM FINISHED FLOOR: 48"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

2:32 PM
Feb. 17, 2011

FROM:



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

2 of 2

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 6696

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 2-17

APPEAL PROPERTY ADDRESS: 1256 RICE ST.

APPLICANT NAME: PUBLIC HEALTH PHONE NUMBER:

PERMIT NUMBER:

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 9.7 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 25" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: 2"

HEIGHT OF OPENING FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT B

2:33PM
Feb. 17, 2011

FROM:




EXHIBIT A

Select a Model

(Model 0201)		0201
Excaltour Double Hung		
Top Sash Width		24.1250
Top Sash Height		25.8750
Bottom Sash Width		25.2500
Bottom Sash Height		25.1250
Top Glass Width		22.5625
Top Glass Height		23.8900
Bottom Glass Width		23.9625
Bottom Glass Height		24.8000
Screen Width	3.1100	33.8125
Screen Height	66.1100	87.6425
Top Sash Weight (plus 5 lb)		20.50
Top Balance Size (oz)		5.9800
Top Balance Size (sq ft)		1.1710
Bottom Sash Weight (lb)		16.75
Bottom Balance Size (oz)		61.60
Bottom Balance Size (sq ft)		25.8750
Net Glass Opening Width		21.0640
Net Glass Opening Height		20.1000
Gross Opening Area (sq ft)		3.2100

⇒ 24 x 50 = 1200 ÷ 144 = 8.3 sq ft

Min. W: 11	Max. W: 52
Min. H: 30	Max. H: 84
Max. Lx: 132	

Equal Size	
Width: 27.5	27.5
Height: 53.5	53.5

Exhaustion: Select Exhaustion
 Opening: Select Size
 Type: Standard
 Screen: 18
 Glass: Double Strength (2 pan)

KC Sash Calender




EXHIBIT B

Select a Model

(Model 0201)
Excaltur Double Hung

Top Sash Width	28.250
Top Sash Height	57.1875
Bottom Sash Width	27.2500
Bottom Sash Height	28.1875
Top Glass Width	24.625
Top Glass Height	25.8000
Bottom Glass Width	25.8125
Bottom Glass Height	26.5000
Screen Width	26.8125
Screen Height	54.8750
Top Sash Weight (Plus 5lb)	22 lb
Top Balance Steel (Std)	96AU
Top Balance Steel (Special)	23JF
Bottom Sash Weight	18 lb
Bottom Balance Steel (Std)	5MAT
Bottom Balance Steel (Special)	21JR
Egress Opening Width	26.6840
Egress Opening Height	22.9000
Egress Opening Area (sq ft)	3.8340

25.8 x 54.6 = 1408 ÷ 9.7 sqft

Min. W: 14 Max. W: 52
Min. H: 20 Max. H: 14 Max. U: 132

Exact Size

Width:	28.5	28.5
Height:	57.5	57.5

Emission: Select Emission
Opening: Exact Size
Type: Standard
Screen: Full
Glass: Double Strength (3 mm)

<< For Arch Top Models Only

42 Sash (optional)