



APPLICATION FOR APPEAL

RECEIVED
FEB 04 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>Feb. 15, 2011</u>
Time <u>1:30 p.m.</u>
Location of Hearing: <u>Room 330 City Hall/Courthouse</u>

mailed 2-4-11

Address Being Appealed:

Number & Street: 1610 Wilson Ave City: St Paul State: MN Zip: 55106

Appellant/Applicant: Window Concepts Email _____

Phone Numbers: Business 6519050105 Residence _____ Cell _____

Signature: _____ Date: _____

Name of Owner (if other than Appellant): Donna Helminiak

Address (if not Appellant's): 1610 Wilson Ave

Phone Numbers: Business 6519050105 Residence 6517717247 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

** State building code says that window meets code if same size & style as original window **

Check: Window Concepts, 990 Lone Oak Rd. #114, Eagan 55121



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: April 26, 2010

APPEAL PROPERTY ADDRESS: 1610 WILSON AVE

APPLICANT NAME: WINDOW CONCEPTS OF MINNESOTA INC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 308815

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1 (one)

Total Glazed Area	7.0 Sq. Ft.	Difference from Required Area	+1.3 Sc. Ft
Width of Opening	27"	Difference from Required Opening	+7"
Height of Opening	16"	Difference from Required Opening	-8"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	

COMMENTS:

Reviewed by David Nelson- Building Inspector