

Other

APPLICATION FOR APPEAL

Saint Paul City Clerk

DEC 3 0 2010

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:	YOUR HEARING Date and 11me:			
\$25 filing fee payable to the City of Saint Paul				
(if cash: receipt number)	Tuesday, /-//-//			
Copy of the City-issued orders or letter which	1.27			
are being appealed	Time			
Attachments you may wish to include	Location of Hearing:			
This appeal form completed	Room 330 City Hall/Courthouse			
Address Being Appealed:				
Number & Street: 129 Bates Auc City: 5				
Appellant/Applicant: Paul Swetland Em	nail jeconstructine each			
Phone Numbers: Business (651) 5488 Residence	•			
Signature:	Date: /2/30110			
Name of Owner (if other than Appellant): Maggie Kess	sell			
Address (if not Appellant's):				
Phone Numbers: Business Residence (651)	292-1166 Cell			
What Is Being appealed and why? Attachments Are Acceptable				
Vacate Order/Condemnation/				
Revocation of Fire C of O	undian Mon-corptonee			
□ Summary/Vehicle Abatement)			
□ Fire C of O Deficiency List				
Fire C of O: Only Egress Windows				
✓ Code Enforcement Correction Notice				
□ Vacant Building Registration				
□ Other				
Other.				



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK 15 KELLOGG BLVD. WEST

310 CITY HALL

SAINT PAUL, MN 55102

DATE: December 21, 2010

APPEAL PROPERTY ADDRESS: 129 BATES AVE

APPLICANT NAME:

J CARVER CONSTRUCTION INC

PHONE NUMBER:

651-266-9027

PERMIT NUMBER:

10 923638

TYPE OF WINDOW

Double Hung

NUMBER OF WINDOWS

Two

Total Glazed Area	10 sq.ft.	Difference from Required Area	+4.3 sq. ft.
Width of Opening	30"	Difference from Required Opening	+10"
Height of Opening	21"	Difference from Required Opening	-3"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	

COMMENTS:

Reviewed by: Dave Nelson

PHONE: 651-266-8688

651-266-8574

FAX: