



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

June 11, 2012

Marvin Lindo
3399 Chandler Rd
Shoreview MN 55126

VIA EMAIL: mlindo@hotmail.com

Re: Appeal for property at 656-658 Lexington Parkway North

Dear Mr. Lindo:

This is to confirm that on June 5, 2012 at the Property Code Hearing, Marcia Moermond, Legislative Hearing recommended that the City Council grant a 2-inch variance on the openable height of the egress windows in the lower level and upper level east bedrooms one; grant a 2.5-inch variance on the openable height of the egress window in the upper level east bedroom 2; grant a 1.5-inch variance on openable height of the egress window in the upper level west bedroom; and deny the appeal and grant an extension to January 1, 2013 to replace or repair the driveway under permit.

This matter will be on the City Council Public Hearing Agenda on Wednesday, July 3, 2012 at 5:30 p.m. in Room 300 Council Chambers if you wish to appeal further.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Sebastian Migdal (email)